BORE WELL DEVELOPMENT CHART (E/M)

SWSM/DWSM

NCC LTD.- GORAKHPUR (UP)

NAME OF THE DISTRICT- Gorakhpur.
NAME OF THE BLOCK- Kauriram.
NAME OF THE GRAM PANCHAYAT- Rahutpar (Rawatpar)
NAME OF THE VILLAGE-
Discharge - 400 LPM.

TYPE OF RIG M/C- RC/DC.
SIZE OF BORE- 550X500
STATIC WATER LEVEL-
J.E Incharge A. Maurya A.E Incharge Babbam yadav.

DEPTH B.G.L IN METER	BORING CHART	STRATA
0M		clay.
24.2M		Medium Sand.
32.6M		Soft clay.
35.4M		Medium Sand.
48.5M		Sandy clay.
73.3M		Medium Sand.
85.7M		clay With Kanker.
98.4M		Coarse Sand.
114.6M		hard clay.
134.2M		Medium Sand.
146.5M		Sandy clay.
158.3M		Medium Sand.
164.6M		clay.

EXECUTED ASSEMBLY



ASSEMBLY DETAILS

200	mm Dia	Housing Pipe A.G.L=	150	m
200	mm Dia	Housing Pipe	0 m to 35.65	m
200	mm Dia	Reducer	35.65 m to 35.85	m
150	mm Dia	Blind pipe	35.85 m to 78.50	m
150	mm Dia	Slotted pipe	78.50 m to 84.50	m
150	mm Dia	Blind pipe	84.50 m to 107.50	m
150	mm Dia	Slotted pipe	107.50 m to 113.50	m
150	mm Dia	Blind pipe	113.50 m to 139.50	m
150	mm Dia	Slotted pipe	139.50 m to 145.50	m
150	mm Dia	Blind pipe	145.50 m to 151.55	m
150	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m
	mm Dia	pipe	m to	m

Total Assembly= 151.55 m + A.G.L (m) = 152.05 m

ABSTRACT

1. Drilling Started-
2. Drilling Completed/Lowering- 23/08/2023
3. Drilling Depth (m)- ~~170~~ Akm 165
4. Assembly Lowered (m)- 152.05
5. Housing Pipe (m)- 36.15
6. Plain Pipe(m)- 97.7
7. Slotted Pipe(m)- 18
8. Reducer(m)- .20

LOGGING REPORT

1- 24 - 32 = 8M
2- 35 - 48 = 13M
3- 73 - 85 = 12M
4- 98 - 114 = 16M
5- 134 - 146 = 12M
6- 158 - 164 = 6M.
7-
8-
9-
10-

SOUND TEST-
VERTICALITY TEST-

AGM	JE & AE	RM/CT/RA	E.E