

BORE WELL DEVELOPMENT CHART (B/M)

SWSM/DWSM

NCC LTD.-GORAKHPUR (UP)

NAME OF THE DISTRICT: Gorakhpur
 NAME OF THE BLOCK: Kauri gram
 NAME OF THE GRAM PANCHAYAT: Dhausa
 NAME OF THE VILLAGE: _____

TYPE OF RIG/MC: Rc/Dc


SIZE OF BORE: 550 X 500 mm

STATIC WATER LEVEL: _____

J.E Incharge: A.K. Mehta A.E. Incharge Baban Yadav

Discharge = 500 LPM

DEPTH BGL IN METER	BORING CHART	STRATA	EXECUTED ASSEMBLY	ASSEMBLY DETAILS
0m			FG.L = 0.5m	200 mm Dia Housing Pipe A.G.L. = 0.5 m
				200 mm Dia Housing Pipe 0 m to 35.65m
				200 mm Dia Reducer 35.65m to 35.85m
				150 mm Dia Blind pipe 35.85m to 53.5m
				150 mm Dia Slotted pipe 53.5m to 59.5m
				150 mm Dia Blind pipe 59.5m to 103.5m
				150 mm Dia Slotted pipe 103.5m to 112.5m
				150 mm Dia Blind pipe 112.5m to 118.5m
				150 mm Dia Slotted pipe 118.5m to 121.5m
				150 mm Dia Blind pipe 121.5m to 127.5m
36.2m				mm Dia pipe m to m
40.5m				mm Dia pipe m to m
50.1m				mm Dia pipe m to m
60.9m				mm Dia pipe m to m
62.6m				mm Dia pipe m to m
67.3m				mm Dia pipe m to m
80.4m				mm Dia pipe m to m
93.2m				mm Dia pipe m to m
99m				mm Dia pipe m to m
100.1m				mm Dia pipe m to m
103.3m				mm Dia pipe m to m
113.5m				mm Dia pipe m to m
118.2				mm Dia pipe m to m
122.0				mm Dia pipe m to m



ABSTRACT

1. Drilling Started- _____

2. Drilling Completed/Lowering- 04/02/2023

3. Drilling Depth (m)- 135m

4. Assembly Lowered (m)- 128.04

5. Housing Pipe (m)- 35.65

6. Plain Pipe (m)- 73.69

7. Slotted Pipe (m)- 18.0 (LCG)

8. Reducer (m)- 0.20

LOGGING REPORT

1. 24-34 = 10m
2. 36-40 = 4m
3. 50-60 = 10m
4. 62-67 = 5m
5. 68-93 = 5m
6. 96-100 = 4m
7. 103-113 = 10m
8. 118-122 = 4m

SOUND TEST:

VERTICALITY TEST:

NCC LTD. LE & AE P.M. CHITRA E.E.