


VINDHYA TELELINKS LIMITED - GAJA ENGINEERING
PVT LTD JV (JJM PHASE-03, SULTANPUR)



Strata Chart & Actual T/W Assembly of Size 300x150 mm Ø of G.P-SHAFIPUR, Block- P.P KAMAICHA.



1	Bore Size	=	600X450 MM
2	Assembly Size	=	300x150 MM
3	Drilling Depth	=	275 mtr
4	Logging Depth	=	273 Mtr
5	Date of Logging	=	22-05-2023
6	Date of Lowering	=	24-05-2023
7	Required Discharge	=	920LPM

Logging Report

S.N.	Depth Range (Mbgl)	Thickness(Mtr)	Remarks
1	10-17	7	Fine to medium sand
2	60-65	5	Fine sand
3	77-83	6	

NOTE:-

1. ALL Zones are highly intermixed with fine bands of kankar. Quality of formation water is deteriorating from 90mbgl to tilted logged depth

SN	PIPE DETAIL	QUANTITY(Mtr)	Remarks
1	300 MM Ø HOUSING PIPE	75.50	
2	150 MM Ø PLAIN PIPE	6.00	
3	300 MM Ø SLOTTED PIPE	11.00	
4	300X150 MM REDUCER	0.20	
TOTAL LOWERING		92.70	
A.G.L		0.50	
B.G.L		92.20	

Prepared by



Contractor

Checked by



Junior Engineer

Recommended by



Assistant Engineer

Approved by



Executive Engineer

M/s Mahalaxmi Tube well

Rajnendra Nagar Pukhrayan Kanpur 9935299290

Geophysical Well Logging Report

Ref No -05/262

Date -24/05/2023

Site Location : - Safipur P.P Kmaichha Sultanpur

District : - Sultanpur

Logged Depth : - ~~273~~ M-BGL

Date of Logging : - 22/05/2023

Types of Log : - S.P& N16, N-64 LAT

Logger used : - ~~IGIS~~

Rm - 12.7 Ω m Rw - 13.5 Ω m

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	10	17	07	Fine to medium Sand	Good
02	59 60	65	06 05	Fine sand	Moderate
03	77	83	06		

Note- All zones are intermixed with fine bands of kankar. Quality of the formation water is deteriorating from 90 Mbgl to tilld logged depth.


- Logging performed as per SWSM guidelines
- Groundwater quality interpreted by firm as per their logger calibration) G.S.H. 24/05/23


M/s Mahalaxmi Tube Well

Date

Mon Tue Wed Thu Fri Sat Sun

Imposed Assembly & State chad of Saji pur Dist. Sultanpur



Discharge : 92000 m³
 Assembly : 300/150
 logging Report

10-12-7
 60-65-5
 77-83-6