

SWSM/DWSM

NCC LTD.- GORAKHPUR (UP)

NAME OF THE DISTRICT- Gorakhpur
 NAME OF THE BLOCK- Kaurisam
 NAME OF THE GRAM PANCHAYAT- Girdharpur Dubey
 NAME OF THE VILLAGE- Discharge - 900 LPM

TYPE OF RIG M/C- RC/DC
 SIZE OF BORE- 600x500
 STATIC WATER LEVEL-
 J.E Incharge A. Nayya A.E Incharge Babbar Yadav

DEPTH B.G.L. IN METER


BORING CHART

STRATA

EXECUTED ASSEMBLY

ASSEMBLY DETAILS

16.2M		Sandy clay
24.6M		Medium Sand
58.3M		clay with Ranigar
68.7M		Medium Sand
85.2M		hard clay
90.8M		Medium Sand
112.3M		Sandy clay
132.7M		Coarse Sand
165M		clay



300	mm Dia Housing Pipe	A.G.L. = .50	m
300	mm Dia Housing Pipe	0	m to 35.62 m
150	mm Dia Reducer	35.62 m to 38.82	m
150	mm Dia Blind pipe	38.82	m to 61.5 m
150	mm Dia Slotted pipe	61.5	m to 67.5 m
150	mm Dia Blind pipe	67.5	m to 85.5 m
150	mm Dia Slotted pipe	85.5	m to 89.5 m
150	mm Dia Blind pipe	89.5	m to 113.5 m
150	mm Dia Slotted pipe	113.5	m to 131.5 m
150	mm Dia Blind pipe	131.5	m to 137.5 m
Total Assembly = 137.54 m + A.G.L. (m) = 138.04 m			

ABSTRACT

1. Drilling Started-
2. Drilling Completed/Lowering- 13/8/04 09/11/23
3. Drilling Depth (m)- 165 Act 150 m
4. Assembly Lowered (m)- 138.04
5. Housing Pipe (m)- 36.12
6. Plain Pipe (m)- 73.72
7. Slotted Pipe (m)- 28
8. Reducer (m)- 20

LOGGING REPORT

- 1- 16-24 = .8M
- 2- 58-68 = 10M
- 3- 85-90 = 5M
- 4- 112-132 = 20M
- 5-
- 6-
- 7-
- 8-
- 9-
- 10-

SOUND TEST-

VERTICALITY TEST-

NCC LTD Ashw J.E & A.E Ashw P.M./C.T./I.A Ashw E.E