



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....

Date...15.12.22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency...M.K.G. Infrastructure Pvt Ltd Meghawan, Associate, Haridwar

Village...Kholeni Block...Khatauli

District...Muzaffer Nagar Logging Depth...150 mt

Drilling Depth...150 mt Water Level...6 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 25	Fine to med Sand	
3	25 - 32	clay loam	
4	32 - 46	Medium Sand	Medium
5	46 - 50	clay loam	
6	50 - 68	Medium Sand	Medium
7	68 - 72	clay loam	
8	72 - 77	Medium Sand	Medium
9	77 - 82	clay loam	
10	82 - 120	Medium Sand	Medium
11	120 - 127	clay loam	
12	127 - 142	Medium Sand	Medium
13	142 - 150	clay loam	
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

S. S. S. S.  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.