



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 5.12.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- NKA Infrastructure Pvt Ltd Max Blower Associates Korhwa
 Village- Maple Rudra Block- Khatauli
 District- Muzaffernagar Logging Depth- 140 mt
 Drilling Depth- 140 mt Water Level- 9 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	clay kaolin	
3	15 - 28	fine sand	
4	28 - 35	clay kaolin	
5	35 - 46	Medium Sand	Hard + good
6	46 - 50	clay kaolin	
7	50 - 74"	Medium Sand	Hard + good
8	74 - 80	clay kaolin	
9	80 - 91"	Medium Sand	Hard + good
10	91 - 97	clay kaolin	
11	97 - 126"	Medium Sand	Hard + good
12	126 - 131	clay kaolin	
13	131 - 140"	fine + med sand	Hard + good
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Enaid
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.