

M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR
 RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111
 8791729831, 7037847205

Ret No

Date 15-11-22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... N K Co. Infra Structure LTD. Muzaffar Nagar
 Village..... Manav Var Pur..... Block..... Khatoli
 District..... Muzaffar Nagar..... Logging Depth..... 148 MTR
 Drilling Depth..... 152 MTR..... Water Level..... 12 MTR

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	0-25	clay	
3	25-54	FINE sand	
4	54-57	clay	
5	57-82	sand medium	
6	82-88	clay	
7	88-94*	sand medium	Good
8	94-100	clay	
9	100-105*	sand medium	Good
10	105-108	clay	
11	108-128*	sand medium	Good
12	128-148	clay konker	
13			
14			
15			
16			
17			
18			
19			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigation