


NAME OF THE DISTRICT- Gorakhpur
 NAME OF THE BLOCK- Khajni
 NAME OF THE GRAM PANCHAYAT- Dangipati
 NAME OF THE VILLAGE- _____
 TYPE OF RIG M/C- RC/DC
 SIZE OF BORE- 600 X 500
 STATIC WATER LEVEL- _____
 J.E Incharge- A. Nagra A.E Incharge- Babbar Yadav

DEPTH B.G.L. IN METER	BORING CHART	STRATA	EXECUTED ASSEMBLY	ASSEMBLY DETAILS
			<u>AGL + 50</u>	<u>300</u> mm Dia Housing Pipe A.G.L. = <u>50</u> m
<u>0M</u>		<u>Sandy clay.</u>		<u>300</u> mm Dia Housing Pipe <u>0</u> m to <u>35.62</u> m
<u>20.84M</u>		<u>Medium Sand.</u>		<u>300</u> mm Dia Reducer <u>35.62</u> m to <u>35.82</u> m
<u>24.4M</u>		<u>Soft clay.</u>		<u>150</u> mm Dia Blind pipe <u>35.82</u> m to <u>40.50</u> m
<u>26.2M</u>		<u>Medium to fine Sand.</u>		<u>150</u> mm Dia Slotted pipe <u>40.50</u> m to <u>49.50</u> m
<u>30.54M</u>		<u>Hard clay.</u>		<u>150</u> mm Dia Blind pipe <u>49.50</u> m to <u>54.50</u> m
<u>35.9M</u>		<u>Sand With Kankar.</u>		<u>150</u> mm Dia Slotted pipe <u>54.50</u> m to <u>68.50</u> m
<u>41.6M</u>		<u>Clay With Kankar.</u>		<u>150</u> mm Dia Blind pipe <u>68.50</u> m to <u>72.50</u> m
<u>50.2M</u>		<u>Medium Sand.</u>		<u>150</u> mm Dia Slotted pipe <u>72.50</u> m to <u>82.50</u> m
<u>70.7M</u>		<u>Hard clay.</u>		<u>150</u> mm Dia Blind pipe <u>82.50</u> m to <u>89.50</u> m
<u>76.4M</u>		<u>Sand With Kankar.</u>		<u>150</u> mm Dia Slotted pipe <u>89.50</u> m to <u>98.50</u> m
<u>82.6M</u>		<u>Soft clay.</u>		<u>150</u> mm Dia Blind pipe <u>98.50</u> m to <u>108.50</u> m
<u>89.2M</u>		<u>Coarse sand</u>		<u>150</u> mm Dia Slotted pipe <u>108.50</u> m to <u>126.50</u> m
<u>99.7M</u>		<u>Sandy clay.</u>		<u>150</u> mm Dia Blind pipe <u>126.50</u> m to <u>138.50</u> m
<u>116.4M</u>		<u>Fine to medium Sand</u>		
<u>120.7M</u>		<u>Sandy clay</u>		
<u>123.3M</u>		<u>Medium Sand</u>		
<u>133.6M</u>		<u>Clay.</u>		
<u>165M</u>				



ASSEMBLY DETAILS	
<u>300</u> mm Dia Housing Pipe	<u>0</u> m to <u>35.62</u> m
<u>300</u> mm Dia Reducer	<u>35.62</u> m to <u>35.82</u> m
<u>150</u> mm Dia Blind pipe	<u>35.82</u> m to <u>40.50</u> m
<u>150</u> mm Dia Slotted pipe	<u>40.50</u> m to <u>49.50</u> m
<u>150</u> mm Dia Blind pipe	<u>49.50</u> m to <u>54.50</u> m
<u>150</u> mm Dia Slotted pipe	<u>54.50</u> m to <u>68.50</u> m
<u>150</u> mm Dia Blind pipe	<u>68.50</u> m to <u>72.50</u> m
<u>150</u> mm Dia Slotted pipe	<u>72.50</u> m to <u>82.50</u> m
<u>150</u> mm Dia Blind pipe	<u>82.50</u> m to <u>89.50</u> m
<u>150</u> mm Dia Slotted pipe	<u>89.50</u> m to <u>98.50</u> m
<u>150</u> mm Dia Blind pipe	<u>98.50</u> m to <u>108.50</u> m
<u>150</u> mm Dia Slotted pipe	<u>108.50</u> m to <u>126.50</u> m
<u>150</u> mm Dia Blind pipe	<u>126.50</u> m to <u>138.50</u> m
Total Assembly = <u>138.50</u> m + A.G.L (m) = <u>139</u> m	

ABSTRACT

1. Drilling Started-
2. Drilling Completed/Lowering-
3. Drilling Depth (m)-
4. Assembly Lowered (m)- 139.
5. Housing Pipe (m)- 36.12
6. Plain Pipe (m)- 78.68
7. Slotted Pipe (m)- 24
8. Reducer (m)- .26

LOGGING REPORT

1. 20-24 = 04 M
2. 26-30 = 04 M
3. 35-41 = 06 M
4. 50-70 = 20 M
5. 76-82 = 06 M
6. 89-99 = 10 M
7. 116-120 = 04 M
8. 128-133 = 05 M
- 9.
- 10.