

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:-B- 208

Date:- 24-04-2023

NAME OF SITE

GRAM PANCHAYAT- Mudia Pamar BLOCK- Sindhali DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging; Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra

.119.✓

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- MUDIA PAMAR, BLOCK- SINDHAULI,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 125 mtrs. depth, and Logged depth 123 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur, a Geophysical well Logging in the above bore hole using IGIS Well Logger on 24.April.2023.

Logging Parameters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Fine sand	
3.	8 - 12	4	Clay kankar	
4.	12 - 18	6	Fine to Medium sand	Good
5.	18 - 24	6	Clay kankar	
6.	24 - 30	6	Fine to Medium sand	Good
7.	30 - 33	3	Clay kankar	
8.	33 - 45	12	Medium sand	Good
9.	45 - 52	7	Clay kankar	
10.	52 - 60*	8	Fine to Medium sand	Good
11.	60 - 65	5	Kankar	
12.	65 - 80	15	Clay kankar	
13.	80 - 88*	8	Medium sand	Good
14.	88 - 95	7	Clay kankar	
15.	95 - 108*	13	Medium sand	Good
16.	108 - 113	5	Clay kankar	
17.	113 - 123*	10	Medium sand	Good


Ground Water Survey Consultancy
Agra

1/1/23

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

① **Fig 1**
 NIS (mV)
 NS4/L10
 LAT
 Logging Details:
 Date: 24 April 2023
 Time: 10:30 AM
 Location: GATEWAY
 Project: GATEWAY
 Client: GATEWAY
 ②
 Logger S. Iyer
 IGS/S/02/22-23
 ③
 SP (mV)
 Logger Vicer:
 DMPL-2
 Logger Cables by:
 GROUND WATER
 SURVEY
 CONSULTANCY
 AGRA, UP, INDIA

