

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-A-443

Date:- 08-05-2023

NAME OF SITE

GRAM PANCHAYAT- Sakarapur BLOCK- Powayan DISTT- Shahjahanpur

NAME OF AGENCY

**M/s NCC Ltd.
Shahjahanpur**



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Phozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- SAKARAPUR, BLOCK- POWAYAN,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 135 mtrs. depth. and Logged depth 132 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 08.May.2023.


Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 7	2	Dry sand	
3.	7 - 25	18	Clay kankar	
4.	25 - 37	12	Medium sand	Good
5.	37 - 47	10	Clay kankar	
6.	47 - 54*	7	Medium sand	Good
7.	54 - 56	2	Clay kankar	
8.	56 - 66*	10	Medium sand	Good
9.	66 - 74	8	Clay kankar	
10.	74 - 82*	8	Medium sand	Good
11.	82 - 90	8	Clay kankar	
12.	90 - 118*	28	Medium sand	Good
13.	118 - 125	7	Clay kankar	
14.	125 - 132*	7	Medium sand	Good

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a

Ni6 (SN)

NS&L(N)

LAT

Logging Details:

Logging GS 30000-Block
Revised: 01/21/22
Date: 01/21/22
Time: 14:11
Station: G-10

Logfile No:

IGIS/01/21-22

SP (m V)

Logger Name:

DMPL-2

Logger Contact:

GROUND WATER
SURVEY
CONSULTANCY
AGRA, UP, India

