



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob.: 9781153000 PFB4625420. Email: gwsc_agra@yahoo.com

of No.

Date: 15.2.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency: J.M.C. - L.C.S.P.L. Laxmi Civil Engg. Services

Village: Nagla khobad Block: Jansath

District: Muzaffar Nagar Logging Depth: 140 mt

Drilling Depth: 143 mt Water Level:

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	Dry Sand	
3	8 - 16	clay loam	
4	16 - 53	Medium Sand	Sand
5	53 - 57	clay loam	
6	57 - 91	Medium Sand	Sand
7	91 - 97	clay loam	
8	97 - 108	Medium Sand	Sand
9	108 - 112	clay loam	
10	112 - 135	Medium Sand	Sand
11	135 - 140	clay loam	
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.