

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:-A- 633

Date:- 26-05-2023

NAME OF SITE

GRAM PANCHAYAT- Dharampura BLOCK- Milak DISTT- Rampur

NAME OF AGENCY

M/s NKG Infrastructure Limited
Delhi



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- DHARAMPURA, BLOCK- MILAK, DISTT- RAMPUR
UNDER
JAL JIVAN MISSION

Introduction :


A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 135 mtrs. at above site. Was drilled by M/s NKG Infrastructure Limited, Delhi.

On the request of M/s NKG Infrastructure Limited, Delhi. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 26.May.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 20	15	Clay	
3.	20 - 35	15	Fine sand	Medium
4.	35 - 43	8	Medium sand	Medium
5.	43 - 47	4	Clay kankar	
6.	47 - 55*	8	Medium sand	Medium
7.	55 - 57	2	Clay kankar	
8.	57 - 80*	23	Medium sand	Medium
9.	80 - 86	6	Clay kankar	
10.	86 - 90*	4	Medium sand	Medium
11.	90 - 95	5	Clay kankar	
12.	95 - 101*	6	Medium sand	Medium
13.	101 - 115	14	Clay kankar	
14.	115 - 127*	12	Medium sand	Medium
15.	127 - 135	8	Clay kankar	

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
 N 16SN
 N 64 UN
 LAT

Project:
 Survey No.:
 Date:
 Scale:
 Contour:
 Sheet No.:

Logger S No.:
 IGIS/S/01/21-22

Logger Model:
 SP

DMP-2

Logger Owned by:
 GROUND WATER
 SURVEY
 CONSULTANCY
 AGRA, UP, India

