

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-A- 1583

Date:- 06-09-2023

NAME OF SITE

GRAM PANCHAYAT- Chaukoni

BLOCK- Shahabad

DISTT- Rampur

NAME OF AGENCY

M/s NKG Infrastructure Limited
Delhi



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- CHAUKONI, BLOCK- SHAHABAD,
DISTT- RAMPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/s NKG Infrastructure Limited, Delhi.

On the request of M/s NKG Infrastructure Limited, Delhi. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 06.Sep.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 14	9	Dry sand	
3.	14 - 22	8	Clay kankar	
4.	22 - 55	33	Fine sand & kankar	Medium
5.	55 - 60	5	Clay kankar	
6.	60 - 79*	19	Medium sand	Medium
7.	79 - 85	6	Clay kankar	
8.	85 - 94*	9	Medium sand	Medium
9.	94 - 103	9	Clay kankar	
10.	103 - 133*	30	Medium sand & kankar	Medium
11.	133 - 138	5	Clay kankar	
12.	138 - 140*	2	Medium sand	Medium

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
NTS (S/C)
NSRQUN
LAT

Logging Details
Logging ID: Chander, East
Dipmeter: Dipmeter
Log Date: 2023
14.55
14.55
14.55

Logger: S. Niaz
IGSS/S/02/22-23

SP (m V)

Logger Model: DMPL-2
Logger Owned by:
GROUND WATER SURVEY CONSULTANCY AGRRA, UP, INDIA

