

# M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR  
 RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111  
 8791729831, 7037847205

Ref No .....

Date 25/12/2022

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency... N.K.G. Infra Structure L.T.D. Muzaffar Nagar  
 village... Jansath DiHAT (Gorhi) Block... Jansath  
 District... Muzaffar Nagar Logging Depth... 154 MTR  
 Drilling Depth... 158 MTR Water Level... 12 MTR

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-24	clay	
3	24-70	Sand medium	
4	70-76	clay	
5	76-97	Sand medium	Good
6	97-104	clay	
7	104-134	Sand medium	Good
8	134-154	clay kankar	
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*[Signature]*  
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations