



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9781163000, 9704625420, Email : gwsc_agra@yahoo.com

No.....

Date 17.1.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency N.K.G. Infrastructure Pvt. Ltd. Meerapur, Meerapur, Meerapur

Village Taxla Block Janseth

District Muzaffargarh Logging Depth 140 m

Drilling Depth 140 m Water Level 15 m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	fine Sand	
3	8 - 12	clay	
4	12 - 25	Sandy clay	
5	25 - 45	Medium Sand	Medium
6	45 - 49	clay loam	
7	49 - 53	Medium Sand	Medium
8	53 - 56	clay loam	
9	56 - 73	Medium Sand	Medium
10	73 - 80	clay loam	
11	80 - 90	Medium Sand	Medium
12	90 - 97	clay loam	
13	97 - 132	Medium Sand	Medium
14	132 - 135	clay loam	
15	135 - 140	Sandy clay	
16			
17			
18			
19			
20			
21			
22			
23			



*Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.