

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-B-2612

Date:- 13-12-2023

NAME OF SITE

GRAM PANCHAYAT- Nawada Ta Bangaon BLOCK- Mirzapur
DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- NAWADA TA BANGAON, BLOCK- MIRZAPUR,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 110 mtrs. depth. and Logged depth 110 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 13.Dec.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 12	7	Fine sand	
3.	12 - 16	4	Clay kankar	
4.	16 - 42	26	Medium sand	Medium
5.	42 - 55	13	Clay kankar	
6.	55 - 68*	13	Medium sand	Medium
7.	68 - 72	4	Clay kankar	
8.	72 - 78*	6	Fine to Medium sand	Medium
9.	78 - 108	30	Clay kankar	
10.	108 - 110	2	Fine sand	Medium

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



File #
 N18 GWT
 N18G110
 LAT

Logging Details
 Dr. Narayan T. Sengupta
 Senior Geologist
 Geosurvey
 11 Dec 2022
 11:52
 Chhatrapati Shivaji Maharaj (CSM)

Logger's No.
 KGS/S/01/21-22

Logger Name:
 SP (m V)
 DAPL-2

Logger Owned By:
 GROUND WATER
 SURVEY
 CONSULTANCY
 AGRA, UP, India

