



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 18.9.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency... M.K.G. Infrastructure Pvt. Delhi, Mae Bhawan Amnarak

Village... Dahkheri... Block... Jansath

District... Muzaffar Nagar Logging Depth... 150 mtr

Drilling Depth... 150 mtr... Water Level... 11 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	Fine Sand	
3	15 - 22	clay kerite	
4	22 - 57	Medium Sand	Good
5	57 - 63	clay kerite	
6	63 - 71	Medium Sand	Good
7	71 - 77	clay kerite	
8	77 - 88	Medium Sand	Good
9	88 - 93	clay kerite	
10	93 - 110	Medium Sand	Good
11	110 - 132	clay kerite	
12	132 - 150	Med to coarse Sand	Good
13			
14			
15			
16			
17			
18			
19			



*Expected Water Bearing Zone

For Ground Water Survey Consultancy

S. Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.