



GSTIN : 09AEOPO8865L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Ferozabad Road, Agra- 282006
 Mob. : 9781163000, 9794625420, Email : gsmc_agra@yahoo.com

Ref No. _____

Date: 6.5.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency: Water Supply Department, Agra
 Village: Maham Ganga Block: Deoria
 District: Mathura Logging Depth: 150 mts
 Drilling Depth: 150 mts Water Level: 6 mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	clay loam	
3	15 - 18	medium sand	Sand
4	18 - 23	clay loam	
5	23 - 26	medium sand	Sand
6	26 - 27	clay loam	
7	27 - 65	medium sand	Sand
8	65 - 71	clay loam	
9	71 - 75	very fine sand	
10	75 - 89	clay loam	
11	89 - 95	fine sand	medium
12	95 - 150	clay loam	
13			
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
 Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations