



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.


Date. 12-05-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency - Welspun Keilbna Industries
 Village - Shiv Nagar & Dusra Block - Shikarpur
 District - Bulandshahar Logging Depth - 150 mtr.
 Drilling Depth - 150 mtr. Water Level - 1.5 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	Dry Sand	
3	8 - 13	clay KanKar	
4	13 - 20	Fine Sand	
5	20 - 23	clay KanKar	
6	23 - 30	Fine Sand	medium
7	30 - 41	clay KanKar	
8	41 - 68*	medium Sand & Kan.	medium
9	68 - 76	clay KanKar	
10	76 - 85*	medium Sand	medium
11	85 - 95	clay KanKar	
12	95 - 105*	medium Sand	medium
13	105 - 129	clay KanKar	
14	129 - 139*	medium Sand	medium
15	139 - 145	clay KanKar	
16	145 - 148	Fine Sand	medium
17	148 - 150	clay KanKar	
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

U.K. Sr
Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.