



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 26-04-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- Well Span PPS Construction
 Village- Isanpur Block- Dampur
 District- Bulandshahr Logging Depth- 15mts
 Drilling Depth- 15mts Water Level- 14 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 7	Dry Sand	
3	7 - 10	clay Kankar	
4	10 - 14	Fine Sand	
5	14 - 22	clay Kankar	
6	22 - 29	Fine Sand	medium
7	29 - 33	clay Kankar	
8	33 - 43	Fine to med. Sand	medium
9	43 - 46	clay Kankar	
10	46 - 65*	medium Sand	medium
11	65 - 72	clay Kankar	
12	72 - 83*	medium Sand	medium
13	83 - 96	clay Kankar	
14	96 - 102*	Fine to med. Sand	medium
15	102 - 124	clay Kankar	
16	124 - 134*	Fine to med. Sand & Skn	medium
17	134 - 140	Sandy clay	
18	140 - 150	clay Kankar	
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

J. K. D.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.