





VINDHYA TELELINKS LTD -GAJA ENGINEERING PVT.LTD.JV
 Actual T.W. Assembly & Strata Chart As Per Logging Report
 G P-, ,Bardsha Block - Bhadaian, Sultanpur
 JJM Phase - III



Actual Assembly for Lowering		
1	Bore Size	500*450 mm
2	T.W. Assembly size	200*150 mm
3	Discharge	600 LPM
5	Date of Logging	11-04-2023
6	Date of lowering	12-04-2023

1	200mm@Plain Pipe	75.00 M
2	200MM@Slotted Pipe	14.00 M
3	150MM@Plain Pipe	6.00 M
4	200*150 Reducer	0.20 M
5	Total Length	96.20 M
6	AGL	(-)0.50
7	Lowering	95.70 M

Logging Report (11-04-23)		
1	17 - 21	04 M
2	77 - 87	10 M



JUNIOR ENGINEER
 DIVISION (EM)
 UP-JAL NIGRAH (E & M)
 UPJN LAYUCHYA


AE E & M
 UPJN

EE E & M
 UPJN


Block - Bhadaiya
 Cr. P - Barshada

Discharge = 600 LPM
 Assembly size = 200 X 150 mm
 Bore ϕ = 500 X 450 mm

- MS plain pipe 200mm ϕ = 76.00 mtr
- MS slotted pipe 200mm ϕ = 14.00 mtr
- MS plain pipe 150mm ϕ = 06.00 mtr
- Reducer 200 X 150 mm ϕ = 01 NO
- MS Ring 200mm ϕ = 17 NOS.
- MS Well cap 200 mm = 01 NO
- MS Ball Plug 150mm = 01 NO
- H-frame 200mm = 01 NO
- SI clamp 200 mm = 01 NO



Proposed TV Assembly chart of Barsatha w/s scheme block Bhadaiyan
Distt. Sultanpur



1. Discharge 600mm
2. Assembly size 200x150mm
3. Bore ϕ 500 x 450mm
4. Logging report of 11-4-23

$$\begin{array}{l}
 1 - 17 - 21 = 4 \\
 2 - 77 - 87 = 10
 \end{array}
 \left. \vphantom{\begin{array}{l} 1 \\ 2 \end{array}} \right\} \text{good}$$

Water formation is deteriorate
 ϕ on 100 mtr bgl till logged down
 297 mtr bgl



M/s Mahalaxmi Tube well

Rajnendra Nagar Pukhrayan Kanpur 9935299290

Geophysical Well Logging Report

Ref No -04/102

Date -12/04/2023

Site Location :- Barsdha Bhadalyan Sultanpur

District :- Sultanpur

Logged Depth :- ~~297 M BGL~~

Date of Logging :- 11/04/2023

Types of Log :- S.P& N16, N-64 LAT

Logger used :- IGIS

Rm - ~~12.8 Ω m~~ Rw - ~~11.7 Ω m~~

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	17	21	04	Fine to medium Sand	All Good
02	77	87	10		

Note- All zones are intermixed with fine bands of kankar. Quality of the formation water is deteriorating from 100 Mbgl tilld logged depth.

- Logging performed as per SWSM guidelines.

- Groundwater quality interpreted by femas per their logger calibration.

M/s Mahalaxmi Tube Well

G.Sh
12/04/23

