



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 23-07-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- well span Krishna Tenders

Village - Baragan Block- Asanya

District- Bulandshahr Logging Depth- 140 mtr

Drilling Depth- 140 mtr Water Level- 8 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	Day Sand	
3	8 - 12	clay KanKar	
4	12 - 18	Fine Sand	
5	18 - 24	clay KanKar	
6	24 - 30	Fine to med. Sand	medium
7	30 - 38	clay KanKar	
8	38 - 57*	medium Sand & Kan.	medium
9	57 - 70	clay KanKar	
10	70 - 80*	Fine to med. Sand	medium
11	80 - 86	clay KanKar	
12	86 - 98*	medium Sand	medium
13	98 - 140	clay KanKar	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.