



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 20.10.22.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- MCG Infrastructure Data Man Sharan Associates Warden

Village - Karsi Daryapur Block - M.R.N.A.

District - Muzaffernagar Logging Depth - 140 m

Drilling Depth - 140 m Water Level - 11 m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 24	fine sand	
3	24 - 30	clay	
4	30 - 36	fine sand	
5	36 - 42	clay water	
6	42 - 55'	medium sand	good
7	55 - 70	clay water	
8	70 - 92'	medium sand	good
9	92 - 100	clay water	
10	100 - 135'	medium sand	good
11	135 - 140	sandy clay	
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Susana
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.