



GSTIN : 09AEOPG8965L2ZJ



**GROUND WATER SURVEY CONSULTANCY**  
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
Mob : 9761963000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No. .... Date 30.7.23

**GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT**  
**DETAIL OF WATER BEARING ZONES**

Name Of Agency- Welspun, Fertilizer, Paper, Textile, etc. industries  
Village- 1. Bahora, 2. Sherpur, 3. ... Block- ...  
District- ... Logging Depth- 140 m  
Drilling Depth- 140 m Water Level- 140 m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 26	Old waste	
4	26 - 60	medium sand	poor
5	60 - 65	shale	
6	65 - 70	fine to medium	poor
7	70 - 82	claystone	
8	82 - 105	fine to medium	poor
9	105 - 140	shale	
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Singh*  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.

