

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:- N-1607

Date:- 26-03-2023

NAME OF SITE

Gram Panchayat- Paina Bujurg BLOCK- Bhawalkhera DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur




GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- PAINA BUJURG, BLOCK- BHAWALKHERA,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 26.Mar.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Dry sand	
3.	8 - 18	10	Clay kankar	
4.	18 - 33	15	Fine sand	Good
5.	33 - 40	7	Clay kankar	
6.	40 - 57*	17	Medium sand	Good
7.	57 - 62	5	Clay kankar	
8.	62 - 98*	36	Medium sand	Good
9.	98 - 107	9	Clay kankar	
10.	107 - 121*	14	Medium sand	Good
11.	121 - 130	9	Clay	

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
 N 16(SN)
 N 64 (LN)
 LAT

Location:
 Dept. of Water Resources,
 Govt. of Uttar Pradesh,
 Lucknow
 Date: 23/04/2022
 Time: 07:25
 Operator: Umesh Gupta (S)
 Well Name:

Project No:
 (GIS/S/04/21-22)

Logset Model:
 SP
 DMP-2

Logset Owned by:
 GROUND WATER
 SURVEY
 CONSULTANCY
 - AGRA, INDIA

