

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 21/11/2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- well Spun PPS. construction
 Village - Badrampur Block- Paharu
 District- Bulandshahr Logging Depth- 145 mtr.
 Drilling Depth- 150 mtr. Water Level- 12 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	clay Komkar	
3	10 - 18	Fine to med. Sand	
4	18 - 25	clay Komkar	
5	25 - 31	Fine to med. Sand	medium
6	31 - 56	clay Komkar	
7	56 - 85*	medium Sand	medium
8	85 - 95	clay Komkar	
9	95 - 106*	Fine to med. Sand	medium
10	106 - 123	clay Komkar	
11	123 - 134	Fine Sand & Kom.	medium
12	134 - 145	clay Komkar	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. S. P.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.