

# **GEO-PHYSICAL WELL ELECTROLOGGING REPORT**

Re No –05/234

Date-21/05/2023

## **NAME OF SITE**

TANDWA  
AMANIAGANJ  
AYODHYA

## **NAME OF AGENCY**

VSAIPPL-SCL (JV)  
HYDERABAD

## **M/S MAHALAXMI TUBE WELL**

**CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-  
LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR  
RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111  
9935299290, 8090118811, mahalaxmitubewell@gmail.com**

**ISO; 9001:2015**

# M/s Mahalaxmi Tubewell

Rajnendra Nagar Pukhrayan Kanpur 9935299290

## Geophysical Well Logging Report

Ref No -05/234

Date-21/05/2023

Site Location : - Tandwa Amaniganj Ayodhya

District : - Ayodhya

Logged Depth : - 148 M BGL

Date of Logging : - 21/05/2023

Types of Log : - S.P& N16, N-64 LAT

Logger used : - IGIS

Rm - 18.5  $\Omega$ m Rw - 18.8  $\Omega$ m

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	44	54	10	Fine to Medium sand	Good
02	58	65	07		
03	71	76	05		
04	79	88	09		
05	112	119	07		

Note- All zones are **highly intermixed** with fine bands of kankar.



M/s Mahalaxmi Tube Well

