

# M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR  
 RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111  
 8791729831, 7037847205


Ref No : .....

Date : 09-02-2023

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name of Agency ... N.K. Co. Infrastructure LTD. Muzaffar Nagar  
 Village ... SHAHJADI Block ... BUDHANA  
 District ... Muzaffar Nagar Logging Depth ... 149 MTR  
 Drilling Depth ... 150 MTR Water Level ... 22 MTR

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 24	Clay	
3	24 - 39	FINE Sand	
4	39 - 51	Clay	
5	51 - 82	Sand medium	Good
6	82 - 91	Clay	
7	91 - 103	Sand medium	Good
8	103 - 121	Clay	
9	121 - 128	Sand medium	Good
10	128 - 149	Clay kankar	
11			
12			
13			
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*[Signature]*  
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations