REPORT ON GEOPHYSICAL WELL LOGGING

GRAM PANCHAYAT- HASAUA, BLOCK- NIGOHI, DISTT- SHAHJAHANPUR UNDER JAL JIVAN MISSION

Introduction:

A Deep bore hole was drilled 142 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 27.June.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Defth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Clay kankar	
3.	10 - 20	10	Medium sand	Good
4.	20 - 25	5	Clay kankar	
5.	25 - 34.	9	Medium sand	Good
6.	34 - 43	9	Clay kankar	
7.	43 - 60*	17	Medium sand	Good
8.	60 - 75	15	Clay kankar	
9,	75 - 82*	7	Medium sand & Kankar	Good
10.	82 - 86	4	Clay kankar	
11.	86 - 104*	18	Medium sand	Good
12.	104 - 117	13	Clay kankar	
13.	117 - 123*	6	Medium sand	Good
14.	123 - 129	6	Clay kankar	
15.	129 - 140*	11	Medium sand	Good

Ground Water Survey Consultancy

Conclusions and Recommendations :-

- 1. The Lithology broadly tallies with that of drill cutting starta chart.
- The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
- The Quality of water is expected Good.
- Expected discharge is 1000 to 1100 L.P.M.
- 5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
- All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist

Ground Water Survey Consultancy

Coppy Vinesa a Son Vicox Om Sentance Crocketous 21 April 12 Vise VIII Rhos Nie (SW. Ohm m B 8 8 70ğ 귱-5 당-ଞ-35-8-5-8-3:-70 75 Depth (m) 8-**8**-8-**%**-ਙ-ੜ-흄-중-12 8 퍙. 135 3



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:- 428

Date: - 22-06-2022

NAME OF SITE

Gram Panchayat- Laxmanpur

BLOCK- Kalan

DISTT- Shahjahanpur

NAME OF AGENCY

Zig at the participation of the second control of the second contr

M/s NCC Ltd. Shahjahanpur



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M): 9412260823, 9794625420, 9761163000, Email: gwsc_agra@yahoo.com

ISO; 9001: 2015

Ground Water Survey Consultancy