

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date..09/02/2024.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... Wellspan Krishna Industries.....
 Village - Sarawa Dadupur..... Block-..... Khurja.....
 District..... Bulandshahr..... Logging Depth..... 140 mtr......
 Drilling Depth-..... 140 mtr...... Water Level..... 12 mtr. App......

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	Dry Sand	
3	12 - 25	Fine Sand	med. to marginally
4	25 - 36	clay Konkaz	
5	36 - 45*	medium sand	medium to marginally saline
6	45 - 60	clay Konkaz	
7	60 - 64	Fine Sand	marginally saline
8	64 - 103	clay Konkaz	
9	103 - 114	Fine to med. sand	marginally saline
10	114 - 123	clay Konkaz	
11	123 - 125	Sandy clay	
12	125 - 140	clay Konkaz	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V.K. D.

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.