



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date...10-09-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency.....Wellspan.....Kushna Industrial.....
 Village -.....Ajijabad.....Block.....Pahala.....
 District.....Bulandshahr.....Logging Depth.....140 mtr.....
 Drilling Depth.....140 mtr.....Water Level.....9 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	clay Kankar	
3	15 - 18	Fine Sand	
4	18 - 24	clay Kankar	
5	24 - 31	Fine to medium sand	med. to good
6	31 - 45	clay Kankar	
7	45 - 55	Kankar & Sand	
8	55 - 70	clay Kankar	
9	70 - 82*	medium Sand	med. to good
10	82 - 90	clay Kankar	
11	90 - 104*	medium Sand	med. to good
12	104 - 120	clay Kankar	
13	120 - 128*	Fine to med. Sand & Kankar	med. to good
14	128 - 140	clay Kankar	
15			
16			
17			
18			
19			
20			
21			
22			
23			

*

Expected Water Bearing Zone

For Ground Water Survey Consultancy

Vishu

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.