



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date. 24-06-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- Welspan Krishna Industries
 Village - Sungapur Patha Block- Sikarpur
 District- Bulandshahr Logging Depth-
 Drilling Depth- 140 mtr. Water Level- 9 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	Dry sand	
3	15 - 21	Fine sand	
4	21 - 26	clay KanKar	
5	26 - 35	Fine to med. Sand	Good
6	35 - 50	clay KanKar	
7	50 - 52	Fine Sand	Good
8	52 - 75	clay KanKar	
9	75 - 90*	medium Sand	Good
10	90 - 95	clay KanKar	
11	95 - 106*	medium Sand	Good
12	106 - 120	clay KanKar	
13	120 - 130	Sand & KanKar.	Good
14	130 - 140	clay KanKar	
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Vishal
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.