



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date.. 10-09-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- wellspoun Krishna Industries
 Village - Alangipur Nainsuth Block- Lakhawati
 District- Bulandshahr Logging Depth- 135 mtr.
 Drilling Depth- 140 mtr. Water Level- 18 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 11	Dry Sand	
3	11 - 20	clay Kankar	
4	20 - 31	Fine to med. Sand	medium
5	31 - 44	clay Kankar	
6	44 - 55*	medium Sand	medium
7	55 - 63	clay Kankar	
8	63 - 66	Fine Sand	medium
9	66 - 74	clay Kankar	
10	74 - 87*	medium Sand	medium
11	87 - 100	clay Kankar	
12	100 - 105*	Fine to med. Sand	medium
13	105 - 110	clay Kankar	
14	110 - 120*	Fine to med. Sand & Kan.	medium
15	120 - 135	clay Kankar	
16			
17			
18			
19			
20			
21			
22			
23			



*

Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. S. K.

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.