
## EO-PHYSICAL WELL ELECTROLOGGING REPORT

Re No-07/236

Date-25/07/2023



## M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO - LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111 9935299290, 8090118811, mahalaxmitubewell@gmail.com

ISO; 9001:2015

## M/s Mahalaxmi Tube well



Rajnendra Nagar Pukhrayan Kanpur 9935299290 mahalaxmitubewell@gmail.com

## **Geophysical Well Logging Report**

Ref No – 07/236 Date -25/07/2023

Site Location : - Ganeshpur Mavai Ayodhya

District : - Ayodhya

Logged Depth : - 162 M BGL

Date of Logging : - 23/07/2023

Types of Log : - S.P& N16, N-64 LAT

Logger used : - IGIS

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr N0	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	23	32	09	HER	
02	49	55	06	Fine to medium Sand	Good
03	92	96	04		
04	101	107	06		

Note- All zones are intermixed with fine bands of kankar. No suitable zones encountered below 115 Mbgl to till logged depth.

M/s Mahalaxmi Tube Well

