



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....

Date.. 08/03/2024

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency-..... wellpura..... Krishna Industries.....  
 Village -..... Shapur..... Block-..... Jahangirabad.....  
 District-..... Bulandshahr..... Logging Depth-..... 140 mtr.....  
 Drilling Depth-..... 140 mtr..... Water Level-..... 9 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 25	clay Kankar	
4	25 - 35	Fine to med. Sand	medium
5	35 - 40	clay Kankar	
6	40 - 53*	medium Sand	medium
7	53 - 65	clay Kankar	
8	65 - 73*	medium Sand	medium
9	73 - 82	clay Kankar	
10	82 - 90*	medium Sand	medium
11	90 - 102	clay Kankar	
12	102 - 115*	medium Sand & Kan.	medium
13	115 - 140	clay Kankar	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			

\*

Expected Water Bearing Zone

For Ground Water Survey Consultancy

Vic  
Pte  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.