

GROUND WATER SURVEY CONSULTANCY  
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL  
ELECTROLOGGING REPORT

Ref No:- 1340

Date:- 08-12-2022

NAME OF SITE

Gram Panchayat- Dabaura Simra

BLOCK- Jaitipur

DISTT- Shahjahanpur

NAME OF AGENCY


M/s NCC Ltd.  
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY  
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.  
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- DABAURA SIMRA, BLOCK- JAIPUR,  
DISTT- SHAHJAHANPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :


A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 140 mtrs.

at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 08.Dec.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 20	15	Fine to Medium sand	Medium
3.	20 - 25	5	Clay kankar	
4.	25 - 35	10	Medium sand	Medium
5.	35 - 40	5	Clay kankar	
6.	40 - 50*	10	Medium sand	Medium
7.	50 - 61	11	Clay kankar	
8.	61 - 73*	12	Medium sand	Medium
9.	73 - 78	5	Clay kankar	
10.	78 - 93*	15	Medium sand	Medium
11.	93 - 100	7	Clay kankar	
12.	100 - 119*	19	Medium sand	Medium
13.	119 - 122	3	Clay kankar	
14.	122 - 126*	4	Fine to Medium sand	Medium
15.	126 - 140	14	Clay kankar	



**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

Rno 2  
 N1E (SN)  
 N64(LN)  
 LAT

10000 to 100000 Ohm m  
 10000 to 100000 Ohm m  
 10000 to 100000 Ohm m  
 10000 to 100000 Ohm m  
 10000 to 100000 Ohm m  
 10000 to 100000 Ohm m  
 10000 to 100000 Ohm m  
 10000 to 100000 Ohm m

SP (mV)

