



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....


Date...17/10/2023.....

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency-..... Wellspour..... P.P.S. Construction.....  
 Village -..... Khediya b. Ksh..... Block-..... Di. bai.....  
 District-..... Bulandshahr..... Logging Depth-..... 150. mtr.....  
 Drilling Depth-..... 150. mtr..... Water Level-..... 13. mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	Dry Sand	
3	15 - 20	dry Kankar	
4	20 - 27	Fine Sand	
5	27 - 36	clay Kankar	
6	36 - 43	medium Sand	med. to Good
7	43 - 50	clay Kankar	
8	50 - 52	Fine Sand	med. to Good
9	52 - 60	clay Kankar	
10	60 - 69*	medium Sand	med. to Good
11	69 - 75	clay Kankar	
12	75 - 85*	Fine to med. Sand	med. to Good
13	85 - 100	clay Kankar	
14	100 - 115*	medium Sand	med. to Good
15	115 - 130	clay Kankar	
16	130 - 143*	medium Sand & Kankar	med. to Good
17	143 - 147	clay Kankar	
18	147 - 150	Fine Sand	med. to Good
19			
20			
21			
22			
23			



\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

*V. S. P. S.*  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.