

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date: 20.5.22.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency: Wood Hill infrastructure Chand Machinery Store
Village: Satholi Haria Block: Rambur Manoharan
District: Saharanpur Logging Depth: 165 mts
Drilling Depth: Water Level: 2 mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-10	fine sand	
3	10-29	clay kaunka	
4	29-34	fine to med sand	Good
5	34-45	clay kaunka	
6	45-48	fine to med sand	Good
7	48-55	clay kaunka	
8	55-65	Medium Sand	Good
9	65-85	clay kaunka	
10	85-108	Medium Sand	Good
11	108-127	clay kaunka	
12	127-138	Medium Sand	Good
13	138-145	clay kaunka	
14	145-152	Sandy clay	
15	152-165	clay kaunka	
16			
17			
18			
19			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Siddhant
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.