

M/S MAHALAXMI TUBE WELL

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR
RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111
8791729831, 7037847205

Ref No


Date 2-2-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONNES


Name Of Agency... Wood Hill Infrastructure L.T.D. Saharanpur
Village... Dug chada Block... Nagal
District... Saharanpur Logging Depth... 163 mtr
Drilling Depth... 165 mtr Water Level... 9 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface soil	
2	5 - 19	clay	
3	19 - 22	fine sand	
4	22 - 39	clay	
5	39 - 56	Sand medium	
6	56 - 59	clay	
7	59 - 74	fine sand	
8	74 - 78	clay	
9	78 - 83*	Sand medium	Good
10	83 - 86	clay	
11	86 - 93*	Sand medium	Good
12	93 - 96	clay	
13	96 - 121*	Sand medium	Good
14	121 - 125	Clay	
15	125 - 144*	Sand medium	Good
16	144 - 163	clay kankar	
17			
18			
19			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy


Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations