

**GROUND WATER SURVEY CONSULTANCY**  
**GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS**

**GEO-PHYSICAL WELL**  
**ELECTROLOGGING REPORT**

Ref No:-B-1524

Date:- 14-08-2023

**NAME OF SITE**

GRAM PANCHAYAT- Dhanora

BLOCK- Dadrol

DISTT- Shahjahanpur

**NAME OF AGENCY**

M/s NCC Ltd.  
Shahjahanpur



**GROUND WATER SURVEY CONSULTANCY**

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- DHANORA, BLOCK- DADROL,  
DISTT- SHAHJAHANPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 111 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 14.Aug.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 13	8	Fine sand	
3.	13 - 20	7	Clay kankar	
4.	20 - 25	5	Fine sand	
5.	25 - 30	5	Clay kankar	
6.	30 - 58*	8	Medium sand	Med to Good
7.	58 - 75	17	Clay kankar	
8.	75 - 91*	16	Medium sand	Med to Good
9.	91 - 96	5	Clay kankar	
10.	96 - 110*	14	Medium sand & kankar	Med to Good
11.	110 - 115	5	Clay kankar	



**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

Rio a  
 N16(SN)  
 N64(LN)  
 LAT

Logging Details  
 Log no. V Chandra Bock  
 Date of Survey 11.11.2023  
 UP LOGS No. 11.A.9.2023  
 12.15  
 (Water Level 11.11.2023)

Logger S/N No. IGIS/S/01/21-22

Logger Model: SP (m V)  
 Logger Model: DMPL-2  
 Logger Owned by: GROUND WATER SURVEY CONSULTANCY AGRA, UP, India

