

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTOLOGGING REPORT

Ref No:-B- 560

Date:- 21-05-2023

NAME OF SITE

GRAM PANCHAYAT- Bhainsta Kala BLOCK- Kanth DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy

Agra

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BHAINSTA KALA, BLOCK- KANTH,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 116 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 21.May.2023.


Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Dry sand	
3.	8 - 17	9	Clay kankar	
4.	17 - 23	6	Fine sand	
5.	23 - 34	11	Clay kankar	
6.	34 - 37	3	Fine sand	Good
7.	37 - 40	3	Clay kankar	
8.	40 - 75*	35	Medium sand & kankar	Good
9.	75 - 80	5	Clay kankar	
10.	80 - 85	5	Fine to Medium sand	Good
11.	85 - 90	5	Clay kankar	
12.	90 - 97*	7	Fine to Medium sand	Good
13.	97 - 100	3	Clay kankar	
14.	100 - 115*	15	Fine to Medium sand	Good
15.	115 - 116	1	Clay kankar	

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

B
 Rhc a
 N16(SX)
 NSAL10
 LAT
 Logging Details
 Project No. 10-111-10-1
 Station No. 10-111-10-1
 Date 21/04/2022
 Time 10:30 AM
 Location
 Project Name
 B
 SP (m V)
 Logger Used
 DMP1-2
 Logger Contact No.
 GROUND WATER
 SURVEY
 CONSULTANCY
 - AGRA INDIA

