



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 22-10-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- wells pwn Krishna Industries

Village - Nyamatapwa Block- Acharya

District- Bulandshahr Logging Depth- 140 mtr.

Drilling Depth- 140 mtr. Water Level- 6 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	clay Konkaz	
3	12 - 18	Fine Sand	
4	18 - 23	clay Konkaz	
5	23 - 31	Fine to med. Sand	medium
6	31 - 46	clay Konkaz	
7	46 - 50*	Fine to med. Sand	medium
8	50 - 62	clay Konkaz	
9	62 - 81*	medium Sand & Kon.	medium
10	81 - 90	clay Konkaz	
11	90 - 92	Fine Sand	marginally saline
12	92 - 109	clay Konkaz	
13	109 - 114	Fine Sand	marginally saline
14	114 - 133	clay Konkaz	
15	133 - 140	Sand & Konkaz	marginally saline
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. K. P.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.