

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-B-2297

Date:- 02-11-2023

NAME OF SITE

GRAM PANCHAYAT- Bhudia

BLOCK- Kanth

DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy

Agra

* Agra *

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BHUDIA, BLOCK- KANTH, DISTT- SHAHJAHANPUR UNDER JAL JIVAN MISSION

Introduction :


A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 136 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 02.Nov.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Clay kankar	
3.	10 - 15	5	Fine sand	
4.	15 - 25	10	Clay kankar	
5.	25 - 32	7	Fine to Medium sand	Med to Good
6.	32 - 40	8	Clay kankar	
7.	40 - 45	5	Fine to Medium sand	Med to Good
8.	45 - 50	5	Clay kankar	
9.	50 - 56*	6	Medium sand	Med to Good
10.	56 - 61	5	Clay kankar	
11.	61 - 74*	13	Medium sand	Med to Good
12.	74 - 80	6	Clay kankar	
13.	80 - 86*	6	Fine to Medium sand	Med to Good
14.	86 - 90	4	Clay kankar	
15.	90 - 95*	5	Fine to Medium sand	Med to Good
16.	95 - 103	8	Clay kankar	
17.	103 - 125*	22	Medium sand	Med to Good
18.	125 - 136	11	Clay kankar	

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
N16 (SN)
NS4(LN)
LAT

Logging Details
Date: 12/12/22
Time: 11:54
Lat: 23.1234
Long: 73.1234

Logger S No: ICS/S/OA/21-22

SP (m V)
Logger Model: DMP1-2

Logger Owned by: SURVEY CONSULTANCY - AGRA INDIA

