

# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

## GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-B- 14

Date:- 06-04-2023

### NAME OF SITE

GRAM PANCHAYAT- Resam      BLOCK- Kanth      DISTT- Shahjahanpur

### NAME OF AGENCY

M/s NCC Ltd.  
Shahjahanpur



## GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy





# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- RESAM, BLOCK- KANTH, DISTT- SHAHJAHANPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :


A Deep bore hole was drilled 135 mtrs. depth. and Logged depth 127 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 06.April.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Dry sand	
3.	10 - 20	10	Clay kankar	
4.	20 - 25	5	Fine sand	Medium
5.	25 - 30	5	Clay kankar	
6.	30 - 36	6	Fine to Medium sand	Medium
7.	36 - 41	5	Clay kankar	
8.	41 - 60*	19	Medium sand	Medium
9.	60 - 66	6	Kankar	
10.	66 - 86*	20	Medium sand	Medium
11.	86 - 94	8	Clay kankar	
12.	94 - 98	4	Fine sand	Medium
13.	98 - 105	7	Clay kankar	
14.	105 - 121*	16	Medium sand	Medium
15.	121 - 127	6	Clay kankar	

Ground Water Survey Consultancy





Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**



Surveying & Survey  
 Station & Earth Dist  
 Measurements  
 10002000/00000  
 24 Apr 2022  
 14:21  
 10002000/00000  
 10002000/00000

K K  
 K K  
 K K  
 K K

SP (mV)

