

# UP TESTING LABORATORY PVT.LTD.

LGF, Aero Business Tower, Chander Nagar, Surya Nagar,  
Ghaziabad, Uttar Pradesh -201011  
Phone No.: 0120-4295002, 9311834218, 9311834216  
E-mail:

## (FIELD BORE LOG CHART)

पिपामा ज.प. फतेहपुर गांव

खारापट

2

Water Table (Meter): ~~11.50~~ 12.50 M FR

Depth of Bore Hole (Meter): 15.00 M.T.R

Date: 30-3-23

Coordinates: 28.999015°  
77.35391°

| Depth in Meters from to | Type of Sample | Sample No. | Visual Field Observations | S.P.T. VALUE |    |    |           | Remarks |
|-------------------------|----------------|------------|---------------------------|--------------|----|----|-----------|---------|
|                         |                |            |                           | N1           | N2 | N3 | N (N2+N3) |         |
| 0.00-0.50               | DS             |            | सिल्टी सैंड               |              |    |    |           |         |
| 1.50-1.85               | UD             |            | "                         |              |    |    |           |         |
| 1.85-2.30               | SPT            |            | सिल्टी सैंड ब्लॉक         | 3            | 4  | 7  | 11        |         |
| 3.00-3.35               | UD             |            | "                         |              |    |    |           |         |
| 3.35-3.80               | SPT            |            | "                         | 4            | 6  | 8  | 14        |         |
| 4.50-4.85               | UD             |            | सिल्टी सैंड               |              |    |    |           |         |
| 4.85-5.30               | SPT            |            | "                         | 5            | 7  | 9  | 16        |         |
| 5.00-6.35               | UD             |            | सिल्टी सैंड               |              |    |    |           |         |
| 6.35-6.80               | SPT            |            | "                         | 6            | 8  | 10 | 18        |         |
| 7.50-7.85               | UD             |            | सिल्टी ब्लॉक              |              |    |    |           |         |
| 7.85-8.30               | SPT            |            | "                         | 7            | 10 | 13 | 23        |         |
| 9.00-9.35               | UD             |            | "                         |              |    |    |           |         |
| 9.35-9.80               | SPT            |            | "                         | 8            | 12 | 15 | 27        |         |
| 10.50-10.85             | UD             |            | सिल्टी सैंड               |              |    |    |           |         |
| 10.85-11.30             | SPT            |            | "                         | 10           | 14 | 17 | 31        |         |
| 12.00-12.35             | UD             |            | सिल्टी सैंड               |              |    |    |           |         |
| 12.35-12.80             | SPT            |            | "                         | 12           | 16 | 19 | 35        |         |
| 13.50-13.85             | UD             |            | "                         |              |    |    |           |         |
| 13.85-14.30             | SPT            |            | सिल्टी सैंड               | 12           | 17 | 21 | 38        |         |
| 15.00-15.35             | UD             |            | "                         |              |    |    |           |         |
| 15.35-15.80             | SPT            |            | "                         | 14           | 20 | 26 | 46        |         |

CHECKED BY

SITE IN-CHARGE  
MOBILE NO

24/3/23

# UP TESTING LABORATORY PVT.LTD.

L.G.F. Aero Business Tower, Chander Nagar, Surya Nagar,  
Ghaziabad, Uttar Pradesh -201011  
Phone No.: 0120-4295002, 9311834218, 9311834216  
E-mail:

## (FIELD BORE LOG CHART)

पिपाना ए.पी. फोडपुर मन्दा

बाराबाद

03

Water Table (Meter): 12.50 म.प.र.

Depth of Bore Hole (Meter): 15.00 म.प.र.

Date: 30-3-23

Coordinates: २८.९९९९६१°  
७७.३५३८५२°

| No. | Depth in Meters from to | Type of Sample | Sample No. | Visual Field Observations | S.P.T. VALUE |    |    |           | Remarks |
|-----|-------------------------|----------------|------------|---------------------------|--------------|----|----|-----------|---------|
|     |                         |                |            |                           | N1           | N2 | N3 | N (N2+N3) |         |
| 1   | 0.00 0.50               | DS             |            | सिंटी सैंड                |              |    |    |           |         |
| 2   | 1.50 1.85               | UD             |            | "                         |              |    |    |           |         |
| 3   | 1.85 2.30               | SPT            |            | सिंटी सैंड कंकड़          |              |    |    |           |         |
| 4   | 3.00 3.35               | UD             |            | "                         | 4            | 4  | 6  | 10        |         |
| 5   | 3.35 3.80               | SPT            |            | सिंटी सैंड कंकड़          |              |    |    |           |         |
| 6   | 4.50 4.85               | UD             |            | सिंटी सैंड                | 4            | 5  | 6  | 11        |         |
| 7   | 4.85 5.30               | SPT            |            | "                         |              |    |    |           |         |
| 8   | 6.00 6.35               | UD             |            | "                         | 5            | 7  | 7  | 14        |         |
| 9   | 6.35 6.80               | SPT            |            | "                         |              |    |    |           |         |
| 10  | 7.50 7.85               | UD             |            | सिंटी किली                | 6            | 9  | 10 | 19        |         |
| 11  | 7.85 8.30               | SPT            |            | "                         |              |    |    |           |         |
| 12  | 8.50 9.35               | UD             |            | "                         | 7            | 10 | 14 | 24        |         |
| 13  | 9.35 9.80               | SPT            |            | सिंटी किली                |              |    |    |           |         |
| 14  | 10.50 10.85             | UD             |            | सिंटी सैंड                | 8            | 12 | 15 | 27        |         |
| 15  | 10.85 11.30             | SPT            |            | "                         |              |    |    |           |         |
| 16  | 12.00 12.35             | UD             |            | "                         | 10           | 14 | 19 | 33        |         |
| 17  | 12.35 12.80             | SPT            |            | सिंटी सैंड                |              |    |    |           |         |
| 18  | 13.50 13.85             | UD             |            | "                         | 12           | 16 | 19 | 35        |         |
| 19  | 13.85 14.30             | SPT            |            | "                         |              |    |    |           |         |
| 20  | 15.00 15.35             | UD             |            | सिंटी सैंड                | 13           | 17 | 22 | 39        |         |
| 21  | 15.35 15.80             | SPT            |            | "                         |              |    |    |           |         |
|     |                         |                |            |                           | 14           | 20 | 27 | 47        |         |

RECEIVED BY

SITE IN-CHARGE  
MOBILE NO

९३११८३४२१८

# UP TESTING LABORATORY PVT.LTD.

LGF, Aero Business Tower, Chander Nagar, Surya Nagar,  
Ghaziabad, Uttar Pradesh -201011  
Phone No.: 0120-4295002, 9311834218, 9311834216  
E-mail:

## (FIELD BORE LOG CHART)

पिपलावा ग्राम फोरेस्ट माजरा

बागपट्ट

0.L

Water Table (Meter): 12.50 m.T.R

Depth of Bore Hole (Meter):

Date: 30-3-23

Coordinates: 28.998853°

77-353925°

| Depth in Meter from 10 | Type of Sample | Sample No. | Visual Field Observations | S.P.T. VALUE |    |    |           | Remarks |
|------------------------|----------------|------------|---------------------------|--------------|----|----|-----------|---------|
|                        |                |            |                           | N1           | N2 | N3 | N (N2+N3) |         |
| 0.00-0.50              | DS             |            | मिट्टी सैंड               |              |    |    |           |         |
| 0.50-1.00              | UD             |            | मिट्टी सैंड कंक           |              |    |    |           |         |
| 1.00-2.00              | SPT            |            | "                         | 3            | 5  | 6  | 11        |         |
| 2.00-3.00              | UD             |            | मिट्टी सैंड कंक           |              |    |    |           |         |
| 3.00-3.80              | SPT            |            | "                         | 4            | 6  | 8  | 14        |         |
| 3.80-4.35              | UD             |            | मिट्टी सैंड               |              |    |    |           |         |
| 4.35-5.30              | SPT            |            | "                         | 4            | 7  | 10 | 17        |         |
| 5.30-6.35              | UD             |            | मिट्टी सैंड               |              |    |    |           |         |
| 6.35-6.80              | SPT            |            | "                         | 5            | 7  | 9  | 16        |         |
| 6.80-7.85              | UD             |            | मिट्टी कंक                |              |    |    |           |         |
| 7.85-8.30              | SPT            |            | "                         | 6            | 9  | 11 | 20        |         |
| 8.30-9.35              | UD             |            | मिट्टी कंक                |              |    |    |           |         |
| 9.35-9.80              | SPT            |            | "                         | 7            | 11 | 14 | 25        |         |
| 9.80-10.85             | UD             |            | मिट्टी सैंड               |              |    |    |           |         |
| 10.85-11.30            | SPT            |            | "                         | 8            | 12 | 16 | 28        |         |
| 11.30-12.35            | UD             |            | "                         |              |    |    |           |         |
| 12.35-12.80            | SPT            |            | "                         | 10           | 16 | 19 | 35        |         |
| 12.80-13.85            | UD             |            | मिट्टी सैंड               |              |    |    |           |         |
| 13.85-14.30            | SPT            |            | "                         | 12           | 18 | 22 | 40        |         |
| 14.30-15.00            | UD             |            | "                         |              |    |    |           |         |
| 15.00-15.80            | SPT            |            | "                         | 13           | 20 | 26 | 46        |         |

SITE IN-CHARGE  
MOBILE NO  
95411111