



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006


Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No..... **GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT** Date 19/08/2024

DETAIL OF WATER BEARING ZONES

Name Of Agency- Wells Pans Krishna Industrial
 Village - Sangra Peer Block- Goudaithi
 District- Bulandshahr Logging Depth- 135 mtr.
 Drilling Depth- 140 mtr. Water Level- 12 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Very Sand	
3	10 - 16	dry Kankar	
4	16 - 20	Fine Sand	
5	20 - 28	clay Kankar	
6	28 - 43	medium Sand	medium
7	43 - 50	clay Kankar	
8	50 - 57*	medium Sand	medium
9	57 - 65	clay Kankar	
10	65 - 71*	Fine to med. Sand	medium
11	71 - 95	clay Kankar	
12	95 - 105*	medium Sand	medium
13	105 - 111	clay Kankar	
14	111 - 125*	medium Sand	medium
15	125 - 135	clay Kankar	
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V.K. Jha
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.