

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....

Date 4.6.23.....

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES


Name Of Agency- Welspun Enterprises Infrastructure & Energy Krishna Indusre

Village - Deoli Block- Gulawathi

District- Bulandshahr Logging Depth- 140 mt

Drilling Depth- 143 mt Water Level- 12 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Snd	
2	5 - 13	clay loam	
3	13 - 19	fine + med Snd	
4	19 - 22	clay	
5	22 - 33	medium Sand	Good
6	33 - 40	clay loam	
7	40 - 56*	medium Sand	Good
8	56 - 60	clay loam	
9	60 - 71*	medium Sand	Good
10	71 - 81	clay loam	
11	81 - 100*	medium Sand	Good
12	100 - 104	clay loam	
13	104 - 121*	medium Sand	Good
14	121 - 140	clay loam	
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Smit  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.