

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date.. 27/02/2024.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... weleprun..... P.P.S..... Construction.....
 Village..... Vijay..... Nagalya..... Block..... Di. bar.....
 District..... Bulandshahr..... Logging Depth..... 150 mtr.....
 Drilling Depth..... 150 mtr..... Water Level..... 11 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 15	clay Kankar	
4	15 - 19	Fine Sand	
5	19 - 24	clay Kankar	
6	24 - 33	medium Sand	med. to good
7	33 - 39	clay Kankar	
8	39 - 41	Fine Sand	med. to good
9	41 - 48	clay Kankar	
10	48 - 58*	medium Sand	med. to good
11	58 - 62	clay Kankar	
12	62 - 65*	Fine to med. Sand	med. to good
13	65 - 79	clay Kankar	
14	79 - 99*	medium Sand	med. to good
15	99 - 102	clay Kankar	
16	102 - 110*	medium Sand	med. to good
17	110 - 115	clay Kankar	
18	115 - 118*	Fine to med. Sand	med. to good
19	118 - 134	clay Kankar	
20	134 - 140*	Fine to med. Sand	med. to good
21	140 - 150	clay Kankar	
22			
23			

* Expected Water Bearing Zone

For Ground Water Survey Consultancy

VK
PT

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.