



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date...08-10-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- Wells pour Krishna Industries
 Village - A.Rapur Tiyana Block- B.B. Nagar
 District- Bulandshahr Logging Depth- 140 mtr.
 Drilling Depth- 140 mtr. Water Level- 0. mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	clay Kankar	
3	12 - 21	Fine Sand	
4	21 - 28	clay Kankar	
5	28 - 37	Fine to med. Sand	med. to Good
6	37 - 41	clay Kankar	
7	41 - 43	Fine Sand	med. to Good
8	43 - 53	clay Kankar	
9	53 - 81*	medium Sand.	med. to Good
10	81 - 91	clay Kankar	
11	91 - 107*	medium Sand & Kank.	med. to Good
12	107 - 116	clay Kankar	
13	116 - 120	Fine Sand	med. to Good
14	120 - 125	clay Kankar	
15	125 - 130*	Fine to med. Sand	med. to Good
16	130 - 140	clay Kankar	
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

VKS
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.