



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....


Date.. 29-08-2023

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency..... S.S. Infrastructure L.P. Sadab Anshari  
 Village ..... Aurangabad Kasera Block..... Diba  
 District..... Bulandshahr Logging Depth..... 150 mtr.  
 Drilling Depth..... 150 mtr. Water Level..... 6 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 15	Fine Sand	
4	15 - 23	clay Konkar	
5	23 - 65*	medium sand & Kon.	Good
6	65 - 82	clay Konkar	
7	82 - 93*	medium sand	Good
8	93 - 122	clay Konkar	
9	122 - 135*	Fine to med. Sand & Kon.	medium
10	135 - 150	clay Konkar	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

*V.K. Pr.*  
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.